

ORIGINAL

Eagletail Water Co. LLC

P.O. Box 157
Tonopah, AZ 85354
928-372-2236



0000107055

January 25th, 2010

Docket Control
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, AZ 85007

Re: Docket No. W-03936A-01-0966
Docket No. W-02450A-01-0966

Decision No. 65277

2010 Annual Water Loss Report

Enclosed please find copies of our water sold and water loss report for the calendar year of 2010. This past year we had a total of fourteen (14) leaks and replaced three (3) meters that were not operating properly resulting in very low usage readings. We have strived to keep our lines leak free; we know we have unaccountable water losses from time to time. These include occasional losses we cannot calculate when a leak occurs.

Our water lines consist of approximately 30 miles of pipe through rural areas. We are unpaid volunteers who diligently respond to leaks and strive to repair them in a timely manner. Our customers help watch for leaks and we continuously monitor our lines and visually inspect monthly when collecting meter reads. Most of our lines as mentioned above are in rural areas and a leak is not always discovered as quickly as we would like and will continue to monitor as best we can.

Please contact me with any questions regarding this report.

Sincerely,

Susan Haas, Statuary Agent
Eagletail Water Co. LLC

Arizona Corporation Commission
DOCKETED

FEB - 2 2010

DOCKETED BY *MM*

AZ CORP COMMISSION
DOCKET CONTROL

2010 FEB - 2 A 9 49

RECEIVED

COMPANY NAME: EAGLETAIL WATER CO LLC

WATER USE DATA SHEET BY MONTH FOR CALENDAR YEAR 2009

MONTH	NUMBER OF CUSTOMERS	GALLONS SOLD	GALLON PUMPED (Thousands)
JANUARY	55	193340	272100
FEBRUARY	54	229850	315900
MARCH	55	362010	627600
APRIL	54	265520	310800
MAY	54	516920	560400
JUNE	54	419040	556400
JULY	56	427420	682600
AUGUST	56	399420	968500
SEPTEMBER	56	316190	1089900
OCTOBER	55	376070	414700
NOVEMBER	56	334260	491100
DECEMBER	55	188960	288500
TOTAL		4029020	6578500

Is the Water Utility located in an ADWR Active Management Area (AMA)?

() Yes

☒ No

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement?

() Yes

☒ No

If yes, provide the GPCPD amount: _____

What is the level of arsenic for each well on your system. _____ mg/l

(If more than one well, please list each separately.)

Note: If you are filing for more than one system, please provide separate data sheets for each system.